



<b>PTW CHECKLIST - NO. 26</b>		<b>Title: Use of Vacuum Truck (Gully Sucker)</b>	
<b>Owner:</b> Capability Coordinator			
<b>Approver:</b> Capability Coordinator		<b>Max Validity Period: 5 yrs</b>	
<b>Permit No.:</b>		<b>Date:</b>	
<b>Latest Rev</b>	<b>Date</b>	<b>Details</b>	<b>Authorised By</b>
8.0	Jan 2016	Full revision	S Elliott

Other Checklists That May Be Relevant: [24](#), [25](#)

HRA Checklists: [9](#), [16](#)

**NOTE:** This checklist to be used in conjunction with [Checklist 24](#).

**PRIOR TO PERMIT ISSUE:**

Tick when done

- |  | Y                        | N                        | NA                       |
|--|--------------------------|--------------------------|--------------------------|
| 1. The requirements of the above referenced HRA(s) have been read and understood   | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| 2. Dangerous Goods / HSNO placards are displayed on the truck.   | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| 3. You have read and understood the contents of the Material Safety Data Sheets (MSDS) for the substance(s) being handled.                         | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| 4. Disposal location for product being collected has been confirmed with PI.<br>Location: _____  | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| 5. If the liquid / waste is to be removed from site, discuss the waste disposal route with PI. STL Waste Management Procedure covers this process. | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |

**PREPARATION:**

- |  |                          |                          |                          |
|--|--------------------------|--------------------------|--------------------------|
| 6. In the event of a site alarm, the engine is to be turned off with key left in the ignition and personnel are to proceed to the muster point by foot.  | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| 7. Is this system one that may contain Mercury contamination? (Refer to <a href="#">Site Mercury Register</a> ) If the answer is yes, refer to Standard Operating Procedure (SOP) <a href="#">STA-01.43</a> and PTW <a href="#">Checklist 25</a> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| 8. Connect the earth continuity cable from the Gully Sucker to a suitable plant earth point. Record result of continuity test on permit form (<10Ω).   | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| 9. Ensure all vapours are vented away from people and any potential ignition sources including the truck.  | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| 10. Hoses in good condition and are within current certification period.   | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |