



PTW CHECKLIST - NO. 19		Title: Use of Lasers, Strobes and Cameras in a Hazardous Area	
Owner: Capability Coordinator			
Approver: Capability Coordinator		Max Validity Period: 5 yrs	
Permit No.:		Date:	
Latest Rev	Date	Details	Authorised By
4.0	Jan 2016	Full Revision	S Elliott

Other Checklists That May Be Relevant: [18](#), [50](#)

HRA Checklists:

Tick when done

- | | Y | N | NA |
|---|--------------------------|--------------------------|--------------------------|
| 1. Consider need to isolate or inhibit fire and gas detection and the implications of doing so. | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| 2. Indicate the light source to be used, ie: laser, strobe, camera, IR thermometer, laser point, survey laser, stroboscope etc.
_____ | | | |
| 3. Has the potential for a laser beam to enter someone's eye been considered and identified on JHA. (Note this can be either by direct line of sight or by reflection from a polished surface). | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |