



<b>PTW CHECKLIST - NO. 57</b>		<b>Title: General Rigging and Lifting Work (other than cranes)</b>	
<b>Owner:</b> Capability Coordinator			
<b>Approver:</b> Capability Coordinator		<b>Max Validity Period: 5 yrs</b>	
<b>Permit No.:</b>		<b>Date:</b>	
<b>Latest Rev</b>	<b>Date</b>	<b>Details</b>	<b>Authorised By</b>
6.0	Jan 2016	Full revision	S Elliott

Other Checklists That May Be Relevant: [24](#), [27](#), [51](#), [55](#)

HRA Checklists:

**PRIOR TO PERMIT ISSUE:**

Tick when done

- |   | Y                        | N                        | NA                       |
|---|--------------------------|--------------------------|--------------------------|
| 1 If pipe work is to be used as the point of lift, approval must be gained from a mechanical engineer. Approval attached. | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| 2 If lifting over or near live process plant, agree controls with PI.   | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |

**PRIOR TO COMMENCING TASK:**

Tick when done

- |   | Y                        | N                        | NA                       |
|---|--------------------------|--------------------------|--------------------------|
| 3 All rigging equipment is in sound condition and within certification and marked with SWL.   | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| 4 Sling protectors shall be used around sharp edges.  | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| 5 Tape, barriers and/or signs have been erected.  | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| 6 Centre of gravity of the load has been determined?  | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| 7 Are tag lines in place where required.  | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| 8 Prior to the use of lifting lugs on manway flange closures, hatches or motors Visual checks have been carried out by a Facilities Inspector or Mechanical Engineer. | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| 9 Lifting plan discussed between all parties immediately prior to lift including Recovery measures.   | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |

10. The PICOL and the Rigger must hold the required competencies as listed below:

Position/Role	Required Competencies And Qualifications (Unit Standards)	Competency held by (insert name)
Person-in-charge of lift (PICOL)	Must hold <b>at least one</b> of the following NZQA Unit Standards: <ul style="list-style-type: none"> <li>• 26350 – Use common rigging equipment to lift and move loads</li> <li>• 9559 – Sling routine loads and communicate during crane operations in a petrochemical workplace</li> <li>• 3789 – Sling regular loads and communicate during crane operations</li> </ul>	
Dogman/Banksman/Rigger/slinger	Must hold at least one the following NZQA Unit Standards or STL approved equivalents: <ul style="list-style-type: none"> <li>• 26350 – Use common rigging equipment to lift and move loads</li> <li>• 9559 – Sling routine loads and communicate during crane operations in a petrochemical workplace</li> <li>• 3789 - Sling regular loads and communicate during crane operations</li> </ul>	